App.	AEA No	Dist No	District Name	School Size			Requested Amount	Total (Est.) Project Cost	Project Description	Building Name
			r Large Districts - (LG FS) - Large Districts	(Maximum	Awa	ard \$150,0	000)			
CO-L-03	9	621	Bettendorf	LG FLS	\$	8,828	\$ 44,484.0	\$ 64,484	This project will meet the fire safety needs of Section 503 Fire Apparatus Roads of the 2003 International Fire Code. Construction of a 520 foot long by 20 foot wide asphalt fire lane to provide City of Bettendorf fire trucks and emergency vehicles access to new addition to Bettendorf Middle School that was completed in August 2008.	Bettendorf Middle School
CO-L-02	9	1611	Davenport	LG FLS	\$	150,000	\$ 150,000.0	\$ 173,000	Smoke detectors, horns/strobes in all corridors, update emergency lighting, heat detectors, duct detectors, upgrade fire doors, sprinkler systems, pull stations, electrical wiring upgrades, all panels to be upgraded to include surge suppression and remote enunciators.	Hayes, Young, Central, West, Walcott
L-02	11	1737	Des Moines Independent	LG FLS	\$	150,000	\$ 150,000.0	\$ 150,000	•	Jackson Elem, Park Avenue Elem

L-01	1	1863	Dubuque	LG FLS	\$ 150,000	\$ 150,000.0	\$ 321,420	Adding smoke detectors in hallways and closets, adding horns and strobe lights, adding addressable fire alarm systems, install a completely new addressable fire alarm system at Kennedy.	Bryant Fulton, Kennedy, Marshall Elementary
CO-L-01	12	6039	Sioux City	LG FLS	\$ 150,000	\$ 150,000.0	\$ 268,800	Install new addressable fire alarm system and upgrade exit/emergency lighting at East High School.	East High School
L-03	11	6957	West Des Moines	LG FLS	\$ 150,000	\$ 150,000.0	\$ 165,480	Replace fire alarm and annunciation system, replace and add addressable smoke detection devices, replace wiring for alarm system, install alpha numeric display fire panel, and install new fire alarm dialer with the code required twin line dial out capabilities.	Crestview Elementary

Fire Safety	e Safety Grant Applicatio Medium Districts - (MED FS) <mark>arded Fire Safety Grants - Medium Districts</mark>				Awa	rd \$100,0	000)				
Awarded F	ire Safet	v Grant	s - Medium Districts		-						
CO-M-02	1	135	Allamakee	MED FLS	\$	29,810	\$	29,810.0	\$ 29,810	At the High School/Junior High, install heat detectors and visual strobes in public restrooms, locker rooms, and install heat detector in superintendent's storage area. At East Elementary, install illuminated exit signs in band, art, and locker rooms. Install emergency lighting in old gymnasium. Treat wood ceiling above stage with fire retardant product. Install heat detection in old gym, art storage, restrooms, library, work room, new gym, and old gym locker rooms. At Waterville Elementary, install illuminated signs, treat classrooms with exposed wood with fire retardant, install heat detection and visual strobes in restrooms, and install smoke detection in library. At West Elementary, install heat detection in all public restrooms.	Elementary, West Elementary, and Waterville.
CO-M-01	11	729	Boone	MED FLS	\$	100,000	\$	100,000.0	\$ 106,861	Fire detection systems (installing corridor smoke detection and updating antiquated systems), construction items (constructing stairwell separations, floor cutoffs and roofs).	Lincoln Elementary, Page Elementary
CO-M-04	11	981	Carlisle	MED FLS	\$	100,000	\$	100,000.0	\$ 360,000	Fire alarm systems will be replaced in its entirety, arrangements made for a remote system monitoring service.	High School and Hartford Upper Elementary
M-04	267	1044	Cedar Falls	MED FLS	\$	1,929	\$	100,000.0	\$ 193,789	Replacing the unrated glazing and door systems in the stairways and corridors, installation of rated doors in science and art classrooms.	Cedar Falls High School

M-01	1	1638	Decorah	MED FLS	\$ 100,000	\$ 100,000.0	\$ 349,260	Heat detection installed to the current fire alarm system, install visual strobe devices connected to the fire alarm system, remove the cover from the smoke detector above wheel chair lift, install smoke detection connected to the fire alarm system, dispose of all chemicals not currently in use, update the current fire alarm system.	Thomas Roberts, John Cline, West Building
M-03	NWAEA	1701	Denison	MED FLS	\$ 97,348	\$ 97,348.0	\$ 97,348	Replace fire alarm systems at the high school and elementary.	Denison High School and Denison Elementary
M-02	15	2169	Fairfield	MED FLS	\$ 55,812	\$ 55,812.0	\$ 55,812	Put into place a non existent fire curtain, providing a separation between a kitchen area and an area heavily occupied by students. Provide a corrective door hold open device, removing door wedges and foot operated hold open devices.	Elementary, Libertyville Elementary, Pence
CO-M-05	1	3029	Howard-Winneshiek	MED FLS	\$ 100,000	\$ 100,000.0	\$ 100,262	Install a completely new fire safety system.	Crestwood Elementary/Junior High
CO-M-07	267	6098	South Tama County	MED FLS	\$ 1,929	\$ 100,000.0	\$ 104,159	Installation of aluminum blinds, construction of corridor through VoAg Shop and fire wall in HS classroom near cafeteria, and installation of all doors, door closers, panic hardware, cover transoms, strobes, emergency lights, seal holes, exit signs, dryer duct, gas shut-off valves, extend MS wall, and remove Alternative HS carpet on wall.	High School, Middle School, Elementary, and Alternative High School

CO-M-03	10	6768	Washington	MED FLS	\$ 100,000	\$ 100,000.0	\$ 122,000	Rework existing layout of smoke and heat detection devices within fire alarm systems, fire alarm system monitored by an off-site service provider, provide emergency lighting at all exterior exit discharge points from buildings, replace existing sign lights with units equipped with battery backup, provide emergency lighting, seal all wall penetrations, open conduit and wall openings with approved fire stopping materials, identify and provide main shut off valves, provide second exits where required, replace insulation and other materials with fire resistive or non-combustible construction and materials, and construct approved smoke doors for elevator lobbies on all floors.	Elementary /
CO-M-06	1	6961	Western Dubuque County	MED FLS	\$ 72,000	\$ 72,000.0	\$ 72,000	Door and hardware replacements in five school buildings.	Bernard Elementary, Cascade Elementary, Cascade High School, Drexler Middle School, Western Dubuque High School

Fire Safety Grant Applicatio Small Districts - (SML FS) (Maximum Award \$25,000)

Awarded F	ire Safety	/ Grant	s - Small Districts		_					
S-11	11	18	Adair Casey	SML FLS	\$	10,080	\$ 10,080.0	\$ 10,0	80 Install fire rated rame and doors, install visual Adair-Casey Elem, Jr/S strobes High	ŗ
CO-S-12	12	63	Akron Westfield	SML FLS	\$	25,000	\$ 25,000.0	\$ 30,7	77 Fire detection devices ties into the fire alarm system, panic hardware for the six fire/smoke doors, heat detection tied into the fire alarm system, fire pull stations for two shop door exits, remove carpet from the wall in band room and install fire proof acoustical wall covering.	
CO-S-08	267	108	Alden	SML FLS	\$	20,471	\$ 20,471.0	\$ 20,4	Replace outdated emergency lighting in shower rooms, install strobes in locker rooms, install heat detectors in locker rooms, install electromagnetic door closure on door between kitchen and storage room, install 15 fire-rated doors, install fire-rated tempered or wire glass in 12 classroom doors, install ground-fault circuit interrupter in home economics and arts rooms, intall external light switch for gymnasium lights, and treat stage curtains with a fire retardant chemical.	loc
CO-S-18	13	252	Anita	SML FLS	\$	25,000	\$ 25,000.0	\$ 28,9	O4 Electrical installations, liquefied petroleum gas, interior wall and ceiling finish and trim in existing buildings, fire alarm and detection system, maintenance of the means of egress.	
CO-S-14	8	333	Armstrong-Ringsted	SML FLS	\$	25,000	\$ 25,000.0	\$ 59,0	28 Removeal and replacement of double doors, work Ringsted Elementary to be done in the handler room.	
S-07	12	423	Aurelia	SML FLS	\$	21,861	\$ 21,861.0	\$ 21,86	Alarm system with a tones distictively different, High School, Middle fire rated doors that close and latch properly with required panic hardware.	

CO-S-03	11	513	Baxter	SML FLS	\$ 9,848	\$ 9,848.0	\$ 9,848	fire alarm system strobes in all general use restrooms, and self-closing devices on classroom
CO-S-04	267	540	BCLUW	SML FLS	\$ 9,646	\$ 9,646.0	\$ 9,646	doors along corridors. Installation of 2 Fireray 5000 Reflective Beam Smoke Detectors in gymnasium, 2 Addressable Heat Detectors and 6 Addressable Smoke Detectors along with a Horn/Strobe in the auditorium/stage area.
S-02	11	1332	Colfax-Mingo	SML FLS	\$ 25,000	\$ 25,000.0	\$ 26,923	At the middle school, install fire alarm strobes in all Colfax-Mingo Middle general use restrooms, install heat or smoke detection in gymnasium, install heat detection in locker rooms, install illuminated exit signs with battery backup at north main exit doors of modular building, install postive latches on all doors opening into stairwells, install self-closing devices on all doors, and repair emergency lights in boys locker room. In Central Office, install manual fire alarm system with pull stations at exit doors, install multiple-station smoke detection system, install smoke detection in hallways, classrooms, and office spaces, and repair all exit signs.

S-14	267	1791	Dike-New Hartford	SML FLS	\$ 20,764	\$ 20,764.0	\$ 20,764	Fire detection systems-installation of necessary smoke detectors in recommended areas. Purchase and treatment of flame retardant material on two wooden lofts. Replacement of vinyl window shades with an approved flame spread rating. Replacement of curtain in gym stage area. Electrical-replace/repair exit signs, replace emergency lighting, labeling of breaker boxes, installation of receptacles, repairing GFI's, installation of heat detectors. Replace some doors to meet fire code.	Dike-New Hartford High School, Dike-New Hartford unior High, Dike Elementary, New Hartford elementary
CO-S-05	GPAEA	657	Eddyville-Blakesburg	SML FLS	\$ 25,000	\$ 25,000.0	\$ 57,250	Project of replacing the current fire alarm system	Eddyville-Blakesburg High School
CO-S-07	267	2007	Eldora-New Providence	SML FLS	\$ 25,000	\$ 25,000.0	\$ 40,173	Replacing the glass in the classroom doors and installing electromagnetic hold-open devices	Eldora-New Providence Elementary
CO-S-16	267	2403	Garner-Hayfield	SML FLS	\$ 25,000	\$ 25,000.0	\$ 28,795	Glass replacement in the high school corridors, install new panic bars and electromagnetic door holders that are wired directly to the fire alarm system.	Garner-Hayfield High School
CO-S-17	8	2493	Gilmore City-Bradgate	SML FLS	\$ 25,000	\$ 25,000.0	\$ 47,904	Replace four doors having the appropriate fire rating also add additional smoke detectors for storage rooms and additional strobes for the locker rooms.	Gilmore City-Bradgate Elementary
S-03	11	2754	Guthrie Center	SML FLS	\$ 25,000	\$ 25,000.0	\$ 25,000	Install fire alarm system, beam detectors with sensitivity, locker room strobes, restroom strobes, door holder connected to existing system, smoke detectors connected to existing lunch room zone.	Elementary, Jr/Sr High

S-08	267	2781	Hampton-Dumont	SML FLS	\$ 21,827	\$ 21,827.0 \$	21,827	At the Dumont building, remove all existing wall materials where needed and replace with Type X fire rated materials, replace one set of double doors with 20 minute 1 3/4" solid core doors, replace outdated electrical panel on stage, and replace the two closet curtains in Mrs. McWilliams room with two 20 minute 1 3/4" solid core fire doors. At North Side Elementary, install 17 electromagnetic door holders connected to fire alarm system, and replace non-rated window glass in 17 classroom doors with fire rated safety glass.	Dumont Intermediate School and North Side Elementary School.
CO-S-10	267	3150	Iowa Falls	SML FLS	\$ 25,000	\$ 25,000.0 \$	48,587	To increase safety conditions in two of the four school district buildings 1. providing doors that allow safe passage of students, staff and visitors, that properly close and latch, and provide strong fire barrier, 2. provide reliable visual guides so that people may safely exit the school in the event of a power outage or emergency, 3. provide comprehensive smoke detection to alert people to a dangerour situation, 4. eliminate electrical hazards.	
CO-S-01	8	3195	Jefferson-Scranton	SML FLS	\$ 25,000	\$ 25,000.0 \$	34,407	Install smoke detection connected to the fire alarm system, install positive latching panic hardware, install smoke seals.	JS MS, JS HS, JS Elementary, JS South Grade
S-05	10	4446	Monticello	SML FLS	\$ 16,203	\$ 16,203.0 \$	16,203		Carpenter Elementary, Shannon Elementary

CO-S-09	297	4599	Nashua-Plainfield	SML FLS	\$ 25,000	\$ 25,000.0	\$ 29	5,000	Kitchen safety (install approved hood and duct extinguishing system above the stoves in all three Kitchens. Upgrade high school alarm system warning devices system (extending to restrooms, locker rooms, and halls).	Nashua-Plainfield Elementary, Middle School, High School
S-17	1	4774	North Fayette	SML FLS	\$ 15,502	\$ 25,000.0	\$ 62	2,960	The fire detection systems will be installed and the present fire alarm system will be updated.	North Fayette High School and Elementary
S-09	267	873	North Iowa	SML FLS	\$ 25,000	\$ 25,000.0	\$ 3	1,000	Fire Alarm Systems, corridors, doors	North Iowa High School
CO-S-15	267	4785	North Tama County	SML FLS	\$ 25,000	\$ 25,000.0	\$ 25	5,567	Door knob/lock replacement & repair, installation of emergency lights and exit signs, and replacement of several doors, closers, and panic hardware.	North Tama Elementary and North Tama High School
CO-S-06	267	4995	Osage	SML FLS	\$ 25,000	\$ 25,000.0	\$ 20	6,636	Commercial kitchen hoods specifically the Middle School kitchens. Corridors classroom doors that are recommended for replacement will be replaced, clear glass windows and display cases will be replaced with wire glass. Fire alarm additional eat detection devises needed in the high school will be added to the fire alarm system.	Osage Middle, Osage High School
S-12	8	5283	Pocahontas Area	SML FLS	\$ 25,000	\$ 25,000.0	\$ 20	6,900	Replace fire extinguishers, provide rated doors equipped with self-closing devices, emergency illuminated EXIT signs with emergency lighting, heat detectors installed, provide the flame spread rating, hood suppression system above the 10 gas burner stove in the kitchen, 5/8 Type X sheet rock.	Pocahontas Area HS/MS

S-10	12	1975	River Valley	SML FLS	\$ 25,000	\$ 25,000.0	\$ 31,500	Fire detection system for alternative classroom addition, exit door for music room complex, enclosure of handicapped exit door and wall.
S-15	8	5868	Sentral	SML FLS	\$ 25,000	\$ 25,000.0	\$ 25,402	Exit signs shall be internally or externally illuminated, move the Fire Alarm Strobe to a visible location, install new doors to be self closing, install positive latching devices, replace several doors to meet fire code, install one hour separation door and a rated roll down door for the concession stand that opens to the corridor.
S-01	12	5949	Sheldon	SML FLS	\$ 25,000	\$ 25,000.0	\$ 38,292	At East Elementary School, provide fire detection in the multi-purpose room by main office. At Sheldon High School & East Elementary HS, provide heat detection in any hazardous areas, horns or bells that provide a distinctive sound different from bell system to give audible warning to all occupants, provide an ansul system for kitchen commercial stove, and provide second exit from the chorus room and band room.
CO-S-11	8	6095	South Hamilton	SML FLS	\$ 24,824	\$ 24,824.0	\$ 24,824	Commercial cooking extinguishing system, install smoke detectors in stairwell and main entrance lobby, install sheetrock on exposed floor joists of stage area, repair, replace and install door closers and electromagnetic hold open device on doors in several locations, replace auditorium door and install panic hardware, install emergency lighting with batter backup for egress, apply flame retardant material to the stage curtains and the curtain in gym balcony.

S-16	1	6175	Starmont	SML FLS	\$ 25,000	\$ 25,000.0 \$	26,062	Provide battery back-up illuminated exit signs, illumination emergency power, door operation, means of egress, remove the non-fire rated glass separating the classrooms from the corridor.	Starmont Elem, Middle, High School
CO-S-19	267	6471	Tripoli	SML FLS	\$ 15,502	\$ 25,000.0 \$	46,670	Repairs to existing doors, purchase of new doors where necessary, and the purchase of new stage curtains.	Elementary and Middle School/High School
CO-S-02	15-16	6592	Van Buren	SML FLS	\$ 22,300	\$ 22,300.0 \$	22,300	Install 22 electromagnetic locks on 12 doors at Stockton Elementary and 10 doors at Douds Elementary. Install three more emergency lights in gymnasium and lunchroom. At Keosauqua 7-12 building, install doors and panic hardware to the study hall/lunchroom to ensure proper separation from the corridor.	Douds Elementary, Stockport Elementary, Van Buren High School,
S-13	267	819	West Hancock	SML FLS	\$ 25,000	\$ 25,000.0 \$	25,000	Install appropriate fire-rated doors, install approved hold-open devices, install panic hardware, install approved exit signs, install heat and smoke detection to augment current system, replace finish materials with appropriate fire-rated materials, install approved heat and duct systems.	WH Elem, WH Middle, WH High School

S-06	267	6985	West Marshall	SML FLS	\$ 25,000	\$ 25,000.0	\$ 26,642	Smoke detectors will be installed in all areas of the West Marshall Middle
								building as identified by the quote we received. School
								The new system would interconnect smoke
								detection on 30-foot centers throughout the
								corridors. Heat detectors would be installed with
								back boxes and ceiling mounts in all areas
								identified. The electrical upgrades required for the
								project would be taken care of.